

AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **CAINGIN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **4:53 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**


| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 2 CFU/mL | <500 CFU/mL |


REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.


REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL


LYNELL J. CAGUNTAS, RMT
Analyst


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **TAMBUBONG**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **5:09 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 3 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.


REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **SAMPALOC**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **5:15 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**


| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 25 CFU/mL | <500 CFU/mL |


REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL


LYNELL J. CAGUNTAS, RMT
Analyst


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5694-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **CAPIHAN**

Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **5:35 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 16 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5695-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **PASEO DE SAN ROQUE**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **5:44 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 15 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5696-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **MAGUINAO GULOD**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **5:54 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**


| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 12 CFU/mL | <500 CFU/mL |


REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL


LYNELL J. CAGUNTAS, RMT
Analyst


Susana P. Quiaoit, MD, FPSP
Head of the Laboratory



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **GARDEN BREEZE**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **6:01 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 40 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5698-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **CRUZ NA DAAN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **6:10 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 8 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.


REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **MAASIM**

Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **6:20 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 16 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL


LYNELL J. CAGUNTAS, RMT

Analyst

Susana P. Quiaoit, MD, FPSP

Head of the Laboratory

CTL#:5700-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **TALACSAN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **8:07 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 8 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5702-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **POBLACION**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **8:26 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 15 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:5703-15



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 3-011-13-LW-2 & 03-0794-15-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

PLDT. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504 / 0923 737 8982 / 0925 525 5505 / 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 17, 2015**

Name of Client: **SAN AGUSTIN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 15, 2015**
Date of Sampling : **DECEMBER 15, 2015**
Time of Sampling : **6:29 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

| Test Performed | Methodology | No. of Positive Tubes (out of 5 tubes) | Result MPN / 100 mL | Standard MPN / 100 mL |
|---------------------------|----------------------------|---|------------------------|--------------------------|
| Total Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Fecal Coliform | Multiple Tube Fermentation | 0 | <1.1 | <1.1 |
| Heterotrophic Plate Count | Pour Plate Method | | 30 CFU/mL | <500 CFU/mL |

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2007) with respect to total coliform bacteria, fecal coliform bacteria, and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2007

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

LYNELL J. CAGUNTAS, RMT
Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory