

AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL :ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **LICO**

Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **4:10 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		6 CFU/mL	<500 CFU/mL

REMARKS:

The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES:

Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition

NOTE:


Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON- ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6828-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: DECEMBER 26, 2017

Name of Client: **PANTUBIG**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **4:15 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		28 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6829-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdti_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **CAINGIN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **4:25 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		260 CFU/mL	<500 CFU/mL

REMARKS:

The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES:

Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition

NOTE:


Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON-ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6830-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **SAMPALOC**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **4:35 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		100 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON-ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6831-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **ULINGAO**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **4:45 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		390 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6832-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **SAN ROQUE**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **5:00 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		355 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON-ARROYO, RMT
Owner Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6833-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **SAN AGUSTIN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **5:28 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		52 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6836-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **DILIMAN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **5:42 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		455 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON-ARBOYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6837-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL: ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **SALAPUNGAN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **5:50 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		10 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON-ARROYO, RMT
Owns Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6838-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430; Cell No. 0925 525 5504 / 0923 737 88982 / 0925 525 5505 / 0917 525 8199

EMAIL: ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **TALACSAN**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **6:30 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		455 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition


NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON- ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6840-17



AMEER DIAGNOSTIC LABORATORY

A DOH ACCREDITED WATER AND DRUG TESTING LABORATORY

DOH Accreditation No.: 03-004-76-LW-2 & 03-0028-16-PFSS-R

A. Mabini St., Mojon, Malolos City (Beside SSS Office)

Tel. No. 662-6448; Globeline: 305 0430 ; Cell No. 0925 525 5504/ 0923 737 88982/ 0925 525 5505/ 0917 525 8199

EMAIL : ameerdtl_lab@yahoo.com

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Date: **DECEMBER 26, 2017**

Name of Client: **LIBIS**
Business Name: **SAN RAFAEL WATER DISTRICT**

PHYSICAL CHARACTERISTICS : **Clear, No Sediments**

SAMPLE DESCRIPTION:

Sample Taken By : **REGINO V. GONZALES**
Date Received : **DECEMBER 21, 2017**
Date of Sampling : **DECEMBER 21, 2017**
Time of Sampling : **6:40 AM**
Place of Sampling : **SAN RAFAEL, BULACAN**
Source of Sample : **DEEPWELL**

Test Performed	Methodology	No. of Positive Tubes (out of 5 tubes)	Result MPN / 100 mL	Standard MPN / 100 mL
Total Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Fecal/ Thermotolerant Coliform	Multiple Tube Fermentation	0	<1.1	<1.1
Heterotrophic Plate Count	Pour Plate Method		325 CFU/mL	<500 CFU/mL

REMARKS: The sample **PASSED** to the Philippine National Standards for Drinking Water (Department of Health 2017) with respect to coliform bacteria and heterotrophic plate count.

REFERENCES: Philippine National Standards for Drinking Water of 2017
Standard Methods for the Examination of Water & Waste Water 22nd Edition

NOTE: Test result is based on sample as received and it is valid for **one (1) month** from the date issued.

RESULT VALID ONLY WITH DRY SEAL

AMIRA DE LEON ARROYO, RMT
Owner/Analyst

Susana P. Quiaoit, MD, FPSP
Head of the Laboratory

CTL#:6841-17